

NERC

NORTH AMERICAN ELECTRIC
RELIABILITY CORPORATION

Assuring a Reliable BPS through the Expansion of Interregional Transfer Capability: NERC ITCS

John Moura, Director of Reliability Assessment and Performance Analysis


MGA

November 18, 2024


RELIABILITY | RESILIENCE | SECURITY




2012 and 2022 Peak Capacity Resource Mix NERC-Wide




2024-2033 Risk Areas



NERC-Wide Summer Peak Demand Changes 2012 and 2022





NERC-Wide Projected Summer Peak Demand Growth (2034)



Recent Examples Highlight Need for Wide-Area Energy Assessments

June 6, 2023: ERCOT, SPP, MISO: A “wind drought” caused 60 GW of installed wind capacity to generate 300 MW



December 24, 2022: PJM: Transmission system during extreme cold weather limited the ability to export to support southern neighbors




Fiscal Responsibility Act (FRA), Section 322

In consultation with the Regional Entities and transmitting utilities, NERC shall conduct a study containing three elements:

1. **Current total transfer capability**, between each pair of neighboring transmission planning regions.
2. A recommendation of **prudent additions to total transfer capability** between each pair of neighboring transmission planning regions that would demonstrably strengthen reliability within and among such neighboring transmission planning regions.
3. Recommendations on **how to meet and maintain the identified total transfer capability**, together with the prudent recommended additions in #2.

The following is a timeline of upcoming key activities:



What the Study **is**:

- Assessed adequacy of North American interregional transmission system
- Foundational, Groundbreaking Work
- Identifies areas that may suffer energy deficiencies under extreme weather and will benefit from additional transfer capability
- Credible technical analysis, with consistent assumptions, and results that are coordinated with the industry
- Sets the stage for more in-depth studies in future

What the Study **is NOT**:

- Does not match every planning region's modeling approaches
- Does not prescribe specific projects
- Does not prescribe the "how", but "what" may be needed
- Does not evaluate market-based dispatched, or operational mitigations
- Is not the final step in the process (FERC will request public comments)
- Does not evaluate economics or policy
- A complete planning study



Varies Widely

- Current transfer capability changes (TTC) as percentage of peak load = 1% to 92% between regions, varying greatly depending on season and online generation dispatch



Transmission May Not Always be a Solution

- New transmission will not always increase transfer capability
- Voltage and dynamic stability limitations will determine how much power can be transferred




Resource Evaluation Cannot be Overlooked


- Many areas do not have sufficient committed generation to meet demand under extreme conditions (2034)
- Canadian system critical to this evaluation




Higher TTCs Will Require Significant Planning and System-Wide Reinforcements

- TTC additions will require more granular stability studies once specific projects are evaluated
- Meaningful TTC additions will not be completed by 2034 without regulatory/legislative changes







Part I Total Import Capabilities as Percentage of 2024 Peak Load (Winter)




Calculated Transfer Capabilities – 2024/2025 Base Case






Energy Assessment: Cold Snap Example


Maximum Daily Load (% of Annual Peak)




Average Daily Wind & Solar Capacity Factor (%)




Daily Thermal Outage Rate (% of Total)




Minimum Daily Margin (% of Load)



Source: ESIG Transmission Resilience Task Force (Telos Energy)
<https://www.esig.energy/transmission-resilience/>



Energy Assessment Maximum Deficiency Identified (Preliminary)



- Capacity expansion determined by projections in Long-Term Reliability Assessment
- Tightening energy margins driven:
 - assumed extreme weather conditions
 - increased load growth
 - on-going retirement of conventional generation
 - shift toward a higher proportion of variable (wind and solar)
 - energy-limited resources (e.g., battery storage).
- Number of hours in these conditions range from 1-20

Prudent Addition Recommendations (Preliminary)





Table ES.1: Recommended Prudent Additions Detail

Transmission Planning Region	Weather Years (WY) / Events	Resource Deficiency Hours	Maximum Deficiency (MW)	Additional Transfer Capability (MW)	Interface Additions (MW)
ERCOT	Winter Storm Uri (WY2021) and nine other events	135	18,926	14,100	Front Range (5,700) MISO-S (4,300) SPP-S (4,100)
MISO-E	WY2020 Heat Wave and two other events	58	5,715	3,000	MISO-W (2,000) PJM-W (1,000)
New York	WY2023 Heat Wave and seven other events	52	3,729	3,700	PJM-E (1,800) Québec (1,900)
SPP-S	Winter Storm Uri (WY2021)	34	4,137	3,700	Front Range (1,200) ERCOT (800) MISO-W (1,700)
PJM-S	Winter Storm Elliott (WY2022)	20	4,147	2,800	PJM-E (2,800)
California North	WY2022 Heat Wave	17	3,211	1,100	Wasatch Front (1,100)
SERC-E	Winter Storm Elliott (WY2022)	9	5,849	4,100	SERC-C (300) SERC-SE (2,200) PJM-W (1,600)
SERC-Florida	Summer WY2009 and Winter WY2010	6	1,152	1,200	SERC-SE (1,200)
New England	WY2012 Heat Wave and two other events	5	984	700	Québec (400) Maritimes (300)
MISO-S	WY2009 and WY2011 summer events	4	629	600	ERCOT (300) SERC-SE (300)
TOTAL				35,000	


Increasing Energy Deficiency Hours




Example of Prudent Addition Analysis: SERC-E (2033)



First Iteration: Utilize Existing Import Capability and Excess Available Generation from Neighbors



Third Iteration: Maximum Support from Neighbors, Prioritized by Excess Available Generation



5,463 MW of Existing Import Capability + 4,100 MW of Prudent Additions =
9,563 MW of Needed Import Capability

Meet Transfer Capability

- Upgrade transmission
- Resources
- Remedial Action Schemes (RAS)
- Dynamic Line Ratings (DLR)
- Advanced conductors
- Power flow control devices

*Grid Enhancing
Technologies*

Maintain Transfer Capability

- Planning studies
- Coordination with neighbors
- Regulatory/policy mechanisms or NERC standards

- Internal resources
- Transmission enhancements to neighbors
 - Resource evaluations
 - Siting and permitting
 - Cost-allocation
- Demand-side management
 - Demand shifting
 - Energy efficiency
 - Demand response
 - Storage

- Understand analysis limitations
- Identify existing projects
- Recommendations are directional
- Prioritize high-risk areas
- Consider implementation barriers
 - Lack of a process and forum to consider large multiregional transmission opportunities
 - Cost allocation and recovery
 - Seams issues
 - Siting and permitting
- Consider each Region's unique circumstances
- Consider a combination of multiple strategies

FERC

- Will post ITCS report for public comment
- Will submit report to Congress with recommendations on statutory changes if any (12 months after comment period ends)

NERC

- Integrate transmission assessment into Long-term Reliability Assessments
- Enhancements to study data and models
- Canadian Analysis



Questions and Answers